



9. Place of use:

DOMESTIC within KOOTENAI County

Township	Range	Section	¼	of	¼	Lot	Acres
50N	05W	25	SE		NW		
50N	05W	25	NE		SW		

10. Do you own the property listed above as place of use? Yes

If your answer is no, describe in remarks below the authority you have to claim this water right.

\_\_\_\_\_  
\_\_\_\_\_

11. Other Water Rights Used:

12. Remarks:

Priority Date Explanation:

DATE WELL WAS COMPLETED AND PUT TO USE

13. Basis of Claim: Beneficial Use

14. Signature(s)

(a.) By signing below, I/We acknowledge that I/We have received, read and understand the form entitled "How you will receive notice in the COEUR D'ALENE-SPOKANE River Basin Adjudication." (b.) I/We do \_\_\_\_\_ do not ~~wish~~ wish to receive and pay a small annual fee for monthly copies of the docket sheet.

Number of attachments: 1

For Organizations:

I do solemnly swear or affirm under penalty of perjury that I am, and I have signed the foregoing document in the space below as the

TRUSTEE of WHITEHEAD TRUST  
Agents Title (please print) Name of Organization(please print)

and that the statements contained in the foregoing document are true and correct.

Signature of Authorized Agent Matson Whitehead Date 6/2/2026

Printed Name of Authorized Agent MATSON WHITEHEAD

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D D0084582  
 Drilling Permlt No. 893850  
 Water right or injection well # \_\_\_\_\_  
 2. OWNER: Matson H Whitehead & Laura B Whitehead  
 Name Living Trust  
 Address 1690 E. Woodstone Dr.  
 City Hayden State ID Zip 83835

3. WELL LOCATION:  
 Twp. 50N North  or South  Rge. 05W East  or West   
 Sec. 25 1/4 SE 1/4 NW

Gov't Lot \_\_\_\_\_ County Kootenai  
 Lat. 47 39.091 (Deg. and Decimal minutes)  
 Long. 116 54.425 (Deg. and Decimal minutes)  
 Address of Well Site 9206 W. Benton Rd.  
 City Coeur d' Alene

Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

5. TYPE OF WORK:  
 New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method/procedure
Bentonite	0	38	1400 lbs.	Overbore

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	116	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4"	-10	360	.200	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) 116'

9. PERFORATIONS/SCREENS:  
 Perforations  Y  N Method Skilsaw  
 Manufactured screen  Y  N Type \_\_\_\_\_  
 Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
340	360	1/4x8	88	4"	PVC	Sch. 200

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
 Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method

11. FLOWING ARTESIAN:  
 Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
 Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:  
 Depth first water encountered (ft) 155 Static water level (ft) 80  
 Water temp. (°F) Cold Bottom hole temp. (°F) Cold  
 Describe access port Welded steel cap

Well test:

Drawdown (foot)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Ballor	Air	Flowing or open
	25	80	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water quality test or comment: \_\_\_\_\_

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	3	Top Soil		X
10	3	12	Brown Sand		X
10	12	38	Sand & Decomposed Granite		X
8	38	116	Decomposed Granite		X
6	116	155	Gray Granite		X
6	155	280	Gray & Green Granite	X	
6	280	325	Fraclured Granite	X	
6	325	360	Gray & Green Granite		X

RECEIVED

JUL 14 2020

IDWR/NORTH

Completed Depth (Measurable): 360'  
 Date Started: May 8, 2020 Date Completed: May 12, 2020

14. DRILLER'S CERTIFICATION:  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name H2O Well Service Inc. Co. No. 448  
 \*Principal Driller Tom Ruel Date 5-13-2020  
 \*Driller Tom McShane Date 5-13-20  
 \*Operator II \_\_\_\_\_ Date \_\_\_\_\_  
 Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.